

File Original and First Copy with  
Department of Ecology  
Second Copy—Owner's Copy  
Third Copy—Driller's Copy

ENTERED

# WATER WELL REPORT

STATE OF WASHINGTON

Start Card No.

W 043575

32/2E/22M

Water Right Permit No.

(1) OWNER: Name John Teeter (Schab) Address 763 W SUNSET DR. CAMANO IS. WA.

(2) LOCATION OF WELL: County ISLAND NW & SW & SE 22 32 N. R. 2E W.M.

(2a) STREET ADDRESS OF WELL (or nearest address) BURBIN LN. CAMANO IS. WA. 98292

(3) PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal ☐  
☐ Irrigation ☐ Test Well ☐ Other ☐  
☐ DeWater

(4) TYPE OF WORK: Owner's number of well (if more than one)

Abandoned ☐ New well ☒ Deepened ☐ Reconditioned ☐ Method: Dug ☐ Bored ☐  
Cable ☒ Driven ☐  
Rotary ☒ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.  
Drilled 240 feet. Depth of completed well 238 ft.

## (6) CONSTRUCTION DETAILS:

Casing installed: ☒ Diam. from 6 ft. to 6 ft.  
Welded ☐ Diam. from +3 ft. to 218 ft.  
Liner installed ☐  
Threaded ☐ Diam. from 6 ft. to 6 ft.

Perforations: Yes ☐ No ☒

Type of perforator used

Size of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Screens: Yes ☒ No ☐

Manufacturer's Name WESCO

Type S/STEEL

Model No.

Diam. 6 Slot size 6 from 228 ft. to 233 ft.

Diam. 6 Slot size 8 from 233 ft. to 238 ft.

Gravel packed: Yes ☐ No ☒ Size of gravel

Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Surface seal: Yes ☒ No ☐ To what depth? 20 ft.

Material used in seal BENTONITE & CLAY

Did any strata contain unusable water? Yes ☐ No ☒

Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_

Method of sealing strata off \_\_\_\_\_

(7) PUMP: Manufacturer's Name UNKNOWN

Type: \_\_\_\_\_ H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level \_\_\_\_\_ ft.

Static level 125 ft. below top of well Date 10/17/94

Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

Artesian water is controlled by \_\_\_\_\_ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☐ No ☒ If yes, by whom?

Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

" " " " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test \_\_\_\_\_

Ball test 40+ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

Air test 40+ gal./min. with stem set at 238 ft. for 1 hrs.

Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_

Temperature of water \_\_\_\_\_ Was a chemical analysis made? Yes ☐ No ☒

## (10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
TOP SOIL (ALL)	0	3
SAND & GRAVEL	3	18
BROWN CLAY	18	32
GRAY CLAY	32	193
GRAY SANDY CLAY	193	202
GRAY SAND (FINE)	202	218
GRAY SAND (MED)	218	240

RECEIVED

FEB 02 1995

DEPT. OF ECOLOGY

RECEIVED

NOV 28 1994

DEPT. OF ECOLOGY

Work started 10/15/94 Completed 10/17/94

## WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME WATKINS WELL DRILLING CO. (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)

Address 556 N SUNSET DR. CAMANO IS. WA.

(Signed) Ken Watkins License No. 0516

(WELL DRILLER)

Contractor's Registration No. WATKINS 1013472 Date 10/17/94

(USE ADDITIONAL SHEETS IF NECESSARY)





WASHINGTON STATE  
DEPARTMENT OF  
ECOLOGY

# Well Tagging Form

Unique Well Tag No: APH262

## RECORD VERIFICATION (check ☒ one)

- ☒ Well Report available *(please attach this form to the well report and submit it to the Ecology Regional Office near you)*
- ☐ Verification inconclusive
- ☐ Well Report not available

## WELL OWNERSHIP IF DIFFERENT FROM WELL REPORT

Name: Burbin Water System

RECEIVED

Street Address: \_\_\_\_\_

APR 24 2007

City: CAMANO ISLAN

State: WA

DEPT. OF ECOLOGY

## WELL LOCATION IF DIFFERENT FROM WELL REPORT

Well Address: 771 W Burbin Ln/R23223-116-0480

City: Camano Island

County: Island

T. 32N

R. 02E W.M.

Sec. 23

NW 1/4 of the SW 1/4

## FOR AGENCY USE ONLY

Latitude: 48 14.64336

Longitude: 122 31.46088

Elevation at land surface 215 feet meters (circle one)

- ☒ GPS
- ☐ Topographic Map
- ☐ Survey
- ☐ Computer generated

- ☐ Digital Altimeter
- ☐ Topographic Map
- ☒ Other: Computer Generated from DEM and GPS XY Coordinates

### Additional Information, if available:

- ☐ Location marked on topographic map *(please attach)*
- ☐ Location marked on air photo *(please attach)*

Tag placed and well  
GPS'd by:



FOR AGENCY USE ONLY

WELL CHARACTERISTICS

Physical Description of well (size of casing, type of well, housing, etc.)

Pumphouse Is To The Left of Property In Green Shack. Wellhead Is Inside Wooden Well Decoration Under Bucket

Location of Well Identification Tag:

Was supplemental tag needed for easy of identifying well?

☐

Yes

☒

No

If yes, where was tag placed?

D	C	B	A
E	F	G	H
M ●	L	K	J
N	P	Q	R

SECTION: 32N/02E-23

COMMENTS:

FOR ECOLOGY WATER RESOURCES PROGRAM ONLY

Water Right # \_\_\_\_\_

Date Issued: \_\_\_\_\_

Circle One:

Application

Permit

Certificate

Claim

Exempt

File Original and First Copy with  
Department of Ecology  
Second Copy—Owner's Copy  
Third Copy—Driller's Copy

ENTERED

# WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. W 043575  
32/2E/22M

Water Right Permit No. \_\_\_\_\_

(1) OWNER: Name John Teeter (Schab) Address 763 W SUNSET DR. CAMANO IS. WA.

(2) LOCATION OF WELL: County ISLAND NW 4 SW 22 32 N. R. 8E W.M.

(2a) STREET ADDRESS OF WELL (or nearest address) BURBIN LN. CAMANO IS. WA. 98222

(3) PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal ☐  
☐ Irrigation ☐ Test Well ☐ Other ☐  
☐ DeWater

(4) TYPE OF WORK: Owner's number of well (if more than one) \_\_\_\_\_  
Abandoned ☐ New well ☒ Method: Dug ☐ Bored ☐  
Deepened ☐ Cable ☐ Driven ☐  
Reconditioned ☐ Rotary ☒ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.  
Drilled 240 feet. Depth of completed well 238 ft.

## (6) CONSTRUCTION DETAILS:

Casing installed: 6 ft. Diam. from 4.3 ft. to 228 ft.  
Welded ☒ Diam. from 4.3 ft. to 228 ft.  
Liner installed ☐ Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Threaded ☐ Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Perforations: Yes ☐ No ☒

Type of perforator used \_\_\_\_\_

SIZE of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Screens: Yes ☒ No ☐

Manufacturer's Name WESCO

Type 5/STEEL

Model No. \_\_\_\_\_

Diam. 6 Slot size 6 from 228 ft. to 233 ft.

Diam. 6 Slot size 8 from 233 ft. to 238 ft.

Gravel packed: Yes ☐ No ☒ Size of gravel \_\_\_\_\_

Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Surface seal: Yes ☒ No ☐ To what depth? 20 ft.

Material used in seal BENTONITE & CLAY

Did any strata contain unusable water? Yes ☐ No ☒

Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_

Method of sealing strata off \_\_\_\_\_

(7) PUMP: Manufacturer's Name UNKNOWN

Type: \_\_\_\_\_ H.P. \_\_\_\_\_

(8) WATER LEVELS: Land-surface elevation above mean sea level \_\_\_\_\_ ft.

Static level 125 ft. below top of well Date 10/17/94

Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

Artesian water is controlled by \_\_\_\_\_ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☐ No ☒ If yes, by whom? \_\_\_\_\_

Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

" " " " " "

" " " " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time Water Level Time Water Level Time Water Level

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

## (10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
TOP SOIL (ALL)	0	3
SAND & GRAVEL	3	18
BROWN CLAY	18	32
GRAY CLAY	32	193
GRAY SAND (FINE)	193	202
GRAY SAND (FINE)	202	218
GRAY SAND (MED.)	218	240

RECEIVED

FEB 02 1995

DEPT. OF ECOLOGY

RECEIVED

APR 24 2007

DEPT. OF ECOLOGY

RECEIVED

NOV 28 1994

WATER RESOURCES

Work started 10/15/94 10/15/94 Completed 10/17/94 10/17/94

## WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME WATKINS WELL DRILLING CO.  
(PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)

Address 556 N SUNSET DR. CAMANO IS. WA.

(Signed) Ken Watkins License No. 0576  
(WELL DRILLER)

Contractor's Registration No. WATKINS WID3472 Date 10/17/94 10/17/94

(USE ADDITIONAL SHEETS IF NECESSARY)

